

Cambridge Rural Water Quality Zone (Z3)								
Schedule 1 Parameters								
	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
Colour	mg/l Pt/Co	20	52	0	0	<1.0	<1.0	<1.0
Turbidity	FTU	4	52	0	0	<0.1	<0.1	<0.1
Odour	Dil Number	0	52	0	0	0	0	0
Taste	Dil Number	0	51	0	0	0	0	0
Sodium	mg/l	200	10	0	0	<9	10.79	14.6
Nitrate (as NO ₃)	mg/l	50	10	0	0	16.9	33.28	41.3
Nitrite (as NO ₂)	mg/l	0.1	10	0	0	<0.006	<0.006	<0.006
Nitrate/Nitrite Ratio	mg/l	1	10	0	0	0.34	0.67	0.83
Aluminium	ug/l	200	10	0	0	<5	<5	<5
Iron	ug/l	200	10	0	0	<4.0	<4.0	5.7
Manganese	ug/l	50	10	0	0	<0.9	<0.9	<0.9
Copper	mg/l	2	10	0	0	0.01	0.05	0.18
Fluoride	mg/l	1.5	10	0	0	0.15	0.17	0.22
Arsenic	ug/l	10	10	0	0	<0.5	<0.5	<0.5
Cadmium	ug/l	5	10	0	0	<0.06	<0.06	<0.06
Chromium	ug/l	50	10	0	0	<0.3	<0.3	0.3
Nickel	ug/l	20	10	0	0	1.4	2.5	8.1
Lead	ug/l	10	10	0	0	<0.5	<0.5	<0.5
Antimony	ug/l	5	10	0	0	<0.1	<0.1	<0.1
Selenium	ug/l	10	10	0	0	0.6	0.78	1.1
PAH	ug/l	0.1	11	0	0	0	0	0
Escherichia coli	No./100ml	0	171	1	0.58	0	0.03	5
Intestinal Enterococci	cfu/100ml	0	10	0	0	0	0	0
Boron	mg/l	1	10	0	0	<0.05	<0.05	<0.05
Benzo(a)pyrene	ug/l	0.01	11	0	0	<0.002	<0.002	<0.002
Trihalomethanes (total)	ug/l	100	12	0	0	1.9	5.44	8.8

Indicator Parameters								
	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
pH		-	52	0	0	7.2	7.35	7.6
Sulphate (as SO ₄)	mg/l	250	10	0	0	24.3	33.1	40.9
Ammonium (as NH ₄)	mg/l	0.5	52	0	0	<0.04	<0.04	<0.04
Total coliforms	No./100ml	0	171	1	0.58	0	0.49	84
3 day count, 22 deg C	cfu/ml	-	52	0	0	0	2.15	58
Free chlorine	mg/l	-	172	0	0	0.03	0.08	0.18
Conductivity	uS/cm	2500	52	0	0	525	562.8	720
Chloride	mg/l	250	10	0	0	22	26	38

* With the exception of the Escherichia coli/ coliform parameter all of the samples collected from this zone in 2019 complied with the Water Supply (Water Quality) (Amendment) Regulations 2018. The unsatisfactory sample was resampled and was found to comply with the regulations.